

Battery periodic replacement of Miura BWMS

Thank you for your cooperation always.

We inform you of **“Battery periodic replacement of Miura BWMS”**.

For PLC and touch panel in control panel, batteries are used to save internal data. In case battery runs out and power supply is stopped, internal data is erased. Therefore, operation data cannot be saved normally and automatic operation is not available.

Replace battery of each equipment every 3 years after commissioning or when “Battery abnormal” notice is issued, whichever comes first.

When you replace battery, replace all batteries of PLC and touch panel (when remote control panel is installed, it is also included).

For the details, please refer to operation manual.

Battery replacement date confirmation label is attached on back of door of control panel.

Scheduled date of battery replacement	
Write date 3 years after date of replacement	
1.	16th/May/2021
2.	
3.	

Figure: Battery replacement date confirmation label

When battery is replaced, write next date of replacement on label.

Write next replacement date which is 3 years after date of replacement.

Please inform us parts No. when battery replacement is needed.

Product name	Parts No.	Note
Battery CJ1W-BAT01	0000-AA8-3893-0	Battery for PLC
Battery PFXZCBBT1	0000-AL7-0927-0	Battery for touch panel
Label Battery Replacement	A014-431-3000-0	Battery replacement date confirmation label

If you have any question, please feel free to contact nearest our office.

We appreciate your continuous support.